

Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H
Heber, CA 92249
TEL. (760) 482-2440 • FAX (760) 353-9951
www.heber.ca.gov

April 10, 2015

Attention: Mrs. Fischer

Subject: March 2015 Monthly Report

On the billing cycle ending on the 25th of March 27,543,000 gallons of water were used by our consumers, an average of 949,000 gallons was used per day.


On March 31, 2015 an electrical glitch caused the distribution pumps to trip. According to the IID, over 400 residents were without power for approximately one hour. Although the Water Plant was not without power, this outage caused the distribution pumps to trip. An operator responded immediately, and reset the pumps within minutes of the electrical glitch. This incident caused low water pressure in the distribution system for a few minutes and the On-Call Operator received 20 customer complaints. I informed Mr. Ketcham from the State Water Board Division of Drinking Water and was advised to take HPUD routine bacteriological samples. Samples were taken to the Imperial County Lab and the results were absent, indicating that no bacteria were present. There was no adverse effect to the water quality or violation because of this incident.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H
Heber, CA 92249
TEL. (760) 482-2440 • FAX (760) 353-9951
www.heber.ca.gov

April 10, 2015

Attention: Mrs. Fischer
General Manager

Subject: Water Distribution Report March 2015

a) Water breaks (0)

b) Service Leak (4)

1. 9 Main Street
2. 65 10th Street
3. 1225 N. Long Trail
4. 1116 Heffernan Avenue

c) Work orders (80)

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Water Distribution Chief Operator
Heber Public Utility District



HEBER PUBLIC UTILITY DISTRICT
Water Treatment Plant and Billing Report
Billing Period : February 24 thru March 25, 2015


Mth. & Yr.	Water		HPUD Offices/ Parks Gallons not invoiced	Difference Water Not accounted	Sewer Influent	Invoiced Water	Invoiced Sewer	Invoiced Trash
	Gals. Produced	Gals. Invoiced						
Mar-14	30,470,000	19,739,013	48,225	10,682,762	18,311,000	\$ 110,650.31	\$ 98,772.35	\$ 40,207.46
Apr-14	36,590,000	24,899,285	415,770	11,274,945	17,856,000	\$ 120,326.04	\$ 98,908.54	\$ 40,341.65
May-14	42,251,000	28,079,149	541,610	13,630,241	18,786,000	\$ 124,318.35	\$ 99,011.19	\$ 40,381.38
Jun-14	49,523,000	31,949,384	573,210	17,000,406	17,457,000	\$ 127,682.67	\$ 99,194.51	\$ 40,447.50
Jul-14	46,290,000	30,997,210	550,480	14,742,310	17,576,000	\$ 132,059.58	\$ 98,840.66	\$ 40,148.41
Aug-14	42,240,000	29,776,621	599,430	11,863,949	17,801,000	\$ 128,549.03	\$ 98,888.47	\$ 40,364.16
Sep-14	39,630,000	25,830,983	1,043,570	12,755,547	18,088,000	\$ 119,731.66	\$ 98,936.31	\$ 40,383.04
Oct-14	34,674,000	24,238,933	673,950	10,367,672	19,563,000	\$ 117,929.12	\$ 98,838.72	\$ 40,160.35
Nov-14	34,351,000	21,407,407	601,490	12,342,103	21,559,000	\$ 113,870.72	\$ 99,037.78	\$ 40,130.68
Dec-14	25,194,000	21,426,940	1,450,380	2,316,680	19,786,000	\$ 115,808.39	\$ 99,067.67	\$ 40,131.37
Jan-15	26,886,000	17,282,967	432,630	9,170,403	20,754,000	\$ 109,681.46	\$ 99,037.87	\$ 40,138.38
Feb-15	27,013,000	16,586,459	411,800	10,014,741	20,458,000	\$ 108,239.11	\$ 99,077.59	\$ 40,052.05
Mar-15	27,543,000	18,024,513	402,780	9,115,707	19,181,000	\$ 110,957.74	\$ 99,131.35	\$ 40,098.74

Totals includes billing for final accounts

To the best of my knowledge, the information is true and correct.

Liz German
 Liz German
 Office Senior Clerk

4/8/2015
 Date



Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H
Heber, CA 92249
TEL. (760) 482-2440 • FAX (760) 353-9951
www.heber.ca.gov

April 9, 2015

Attention: Laura Fischer
General Manager

SUBJECT: Heber W.W.T.P. Operations from February 24, 2015 to
March 25, 2015

- A. Major violations (NONE)
- B. Minor violations (NONE)
- C. Major sewer spills (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System working fine, no problems.

- F. From February 24, 2015 through March 25, 2015:
Heber Wastewater Plant received and treated 19.181 MG.

- G. HPUD did not exceed the daily maximum flow (1.2 MGD) as
of March 25, 2015.

Sincerely,

A handwritten signature in blue ink, appearing to read "E. Gonzalez", is written over a light blue horizontal line.

Edoardo S. Gonzalez
Wastewater Plant Operator