



Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H
Heber, CA 92249
TEL. (760) 482-2440 • FAX (760) 353-9951
www.heber.ca.gov

June 12, 2015

Attention: Mrs. Fischer

Subject: May 2015 Monthly Report

On the billing cycle ending on the 25th of May 36,450,000 gallons of water were used by our consumers, an average of 1,139,000 gallons was used per day.

On May 5, 2015 clarifier valve was stuck closed causing lower flows through the filter. The actuator is an external part of the valve which opens and closes the valve by a signal send by the program (SCADA). The faulty actuator was replaced and is now working properly. There were no water quality issues or violation because of this incident.


On May 27, 2015 the containment for the Ferric Sulfate was delivered and installed. As a reminder, last month the Brenntag Chemical driver accidently struck the Ferric Sulfate containment causing damage to the structure and spilling approximately 5 gallons of the chemical. Brenntag Chemical Company provided a new containment for the 300 gallon Ferric Sulfate tank and removed contaminated soil from HPUD property. There was no violation because of this incident.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H
Heber, CA 92249
TEL. (760) 482-2440 • FAX (760) 353-9951
www.heber.ca.gov

June 12, 2015

Attention: Mrs. Fischer
General Manager

Subject: Water Distribution Report May 2015

A) Water breaks (0)

B) Service Leak (2)


1. 190 E. Main Street
2. 26 2nd Street

C) Work orders (82)

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Water Distribution Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H
Heber, CA 92249

TEL. (760) 482-2440 • FAX (760) 353-9951

www.heber.ca.gov

June 10, 2015

Attention: Laura Fischer
General Manager

SUBJECT: Heber W.W.T.P. Operations from April 24, 2015 to
May 25, 2015

- A. Major violations (NONE)
- B. Minor violations (NONE)
- C. Major sewer spills (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System working fine, no problems.

- F. From April 24, 2015 through May 25, 2015:
Heber Wastewater Plant received and treated 19.316 MG.

- G. HPUD did not exceed the daily maximum flow (1.2 MGD) as
of May 25, 2015.

Sincerely,

A handwritten signature in blue ink, appearing to be "E. Gonzalez", written over a horizontal line.

Edoardo S. Gonzalez
Wastewater Plant Operator



HEBER PUBLIC UTILITY DISTRICT
Water Treatment Plant and Billing Report
Billing Period :April 24 thru May 25, 2015

Mth. & Yr.	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced
	Gals. Produced	Gals. Invoiced	Gallons not invoiced	Not accounted	Influent	Water	Sewer	Trash
May-14	42,251,000	28,079,149	541,610	13,630,241	18,786,000	\$ 124,318.35	\$ 99,011.19	\$ 40,381.38
Jun-14	49,523,000	31,949,384	573,210	17,000,406	17,457,000	\$ 127,682.67	\$ 99,194.51	\$ 40,447.50
Jul-14	46,290,000	30,997,210	550,480	14,742,310	17,576,000	\$ 132,059.58	\$ 98,840.66	\$ 40,148.41
Aug-14	42,240,000	29,776,621	599,430	11,863,949	17,801,000	\$ 128,549.03	\$ 98,888.47	\$ 40,364.16
Sep-14	39,630,000	25,830,983	1,043,570	12,755,547	18,088,000	\$ 119,731.66	\$ 98,936.31	\$ 40,383.04
Oct-14	34,674,000	24,238,933	673,950	10,367,672	19,563,000	\$ 117,929.12	\$ 98,838.72	\$ 40,160.35
Nov-14	34,351,000	21,407,407	601,490	12,342,103	21,559,000	\$ 113,870.72	\$ 99,037.78	\$ 40,130.68
Dec-14	25,194,000	21,426,940	1,450,380	2,316,680	19,786,000	\$ 115,808.39	\$ 99,067.67	\$ 40,131.37
Jan-15	26,886,000	17,282,967	432,630	9,170,403	20,754,000	\$ 109,681.46	\$ 99,037.87	\$ 40,138.38
Feb-15	27,013,000	16,586,459	411,800	10,014,741	20,458,000	\$ 108,239.11	\$ 99,077.59	\$ 40,052.05
Mar-15	27,543,000	18,024,513	402,780	9,115,707	19,181,000	\$ 110,957.74	\$ 99,131.35	\$ 40,098.74
			high due to sewer plant					
Apr-15	35,351,000	33,459,294	10,188,590	1,891,706	19,371,000	\$ 119,590.57	\$ 99,077.40	\$ 40,060.27
May-15	36,450,000	25,680,055	933,970	9,835,975	19,316,000	\$ 121,795.38	\$ 98,988.32	\$ 40,008.93

Totals includes billing for final accounts

To the best of my knowledge, the information is true and correct.


 Liz German
 Office Senior Clerk

6/11/15
 Date