



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

July 10, 2018

Attention: Mrs. Fischer

Subject: June 2018 Monthly Report

On the billing cycle ending on the 22nd of June 33,326,000 gallons of water were used by our consumers, an average of 1,075,000 gallons was used per day.

On June 4, 2018 ferric pumps at static mixer station ceased due to a leak. The ferric sulfate entered the motor causing the malfunction. The manufacture was notified and within a few days a technician came and made repairs to the piping and the pump motor. The chemical was confined within the concrete containment. There was no violation because of this incident.

On June 15, 2018 the hypochlorite system chiller malfunctioned. The chiller is used to cool the water going thru the cells. The cool water helps to extend the life of cells and maintain a steady chlorine concentration. The manufacture was informed and made some recommendation in order to continue to produce chlorine. They also sub contracted a local Air Conditioning Company to make the necessary repairs. The chiller is now operational. There was no violation because of this incident.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez

Chief Operator

Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

July 09, 2018

Attention: Mrs. Fischer  
General Manager

Subject: Water Distribution Report June 2018

A) Water breaks ( 2 )

1. 1119 Heber Ave
2. 1115 Grand Ave

B) Service Leak ( 0 )


C) Work Orders (106)

LEAK - METER LEAK-----	2
DIS - DISCONNECT-----	7
CON - CONNECT-----	7
INFO - TEST METER -----	4
MC - METER CHANGE -----	29
OCC - OCCUPANT CHANGE-----	0
MISC-MISC REPORT -----	1
HYDRT-HYDRANT LEAK-----	0
TEMP-TEMP SHUT OF REPAIR-----	1
SWR-SEWER PLUG UP-----	0
FIREFLY-FIREFLY REPLACE-----	53
ODOR - ODOR(TASTE/SMELL) -----	2
<b>TOTAL ALL CODES -----</b>	<b>106</b>

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez  
Water Distribution Chief Operator  
Heber Public Utility District



## Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H  
Heber, CA 92249  
TEL. (760) 482-2440 • FAX (760) 353-9951  
www.heber.ca.gov

July 10, 2018

Attention: Laura Fischer  
General Manager


SUBJECT: Heber W.W.T.P. Operation from May 22, 2018 to June 22, 2018

- A. Major violations: (NONE)
- B. Minor violations (NONE)
- C. Major sewer spills (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System: Operating fine. Self- Cleaning. No Maintenance.
- F. Vactor Truck: From June 6 to June 8 2018, the vactor truck was used to clean sewer lines from Parkyns lift station going east to Heffernan Avenue and from Heffernan Avenue by the Barber Shop to 6<sup>th</sup> st. Sewer line from 6<sup>th</sup> st. and Heffernan going east towards railroad track were also cleaned.
- G. TOTAL OF MILES CLEANED : Approximately 1200 (.23miles) feet of sewer line were cleaned between May 22, 2018 and June 22, 2018.
- H. From May 22, 2018 through June 22, 2018:  
Heber Wastewater Plant received and treated 14.047 MG.
- I. HPUD did not exceed the daily maximum flow (1.2 MGD) as of June 22, 2018.

Sincerely,

A handwritten signature in blue ink, appearing to be "E. Gonzalez", written over a light blue circular stamp.

Edoardo S. Gonzalez  
Wastewater Plant Operator



**HEBER PUBLIC UTILITY DISTRICT**  
**Water Treatment Plant and Billing Report**  
**Billing Period : April 22, 2018 thru May 22, 2018**

<i>Mth. &amp; Yr.</i>	<i>Water</i>		<i>HPUD Offices/Parks</i>	<i>Difference Water</i>	<i>Sewer</i>	<i>Invoiced</i>	<i>Invoiced</i>	<i>Invoiced</i>	<i>10% Senior Discount</i>
	<i>Gallons Produced</i>	<i>Gallons Invoiced</i>	<i>Gallons not invoiced</i>	<i>Water not accounted</i>	<i>Influent</i>	<i>Water</i>	<i>Sewer</i>	<i>Trash</i>	<i># of Accounts receiving the discount</i>
May-17	37,175,000	26,263,237	1,364,143	9,547,620	14,928,000	\$ 122,488.65	\$ 100,029.46	\$ 41,402.03	-
Jun-17	43,530,000	31,613,609	1,439,099	11,773,292	14,481,000	\$ 133,896.35	\$ 99,862.17	\$ 41,345.46	-
Jul-17	41,907,000	32,289,352	1,497,306	8,120,342	13,402,000	\$ 140,711.94	\$ 97,991.51	\$ 41,664.23	44 Accounts
Aug-17	41,160,000	31,401,126	1,659,102	8,099,772	13,570,000	\$ 137,488.33	\$ 98,196.57	\$ 41,576.85	71 Accounts
Sep-17	36,291,000	30,248,999	2,067,177	3,974,824	14,380,000	\$ 134,264.75	\$ 98,046.65	\$ 41,602.82	82 Accounts
Oct-17	36,098,000	27,671,827	3,021,435	8,426,173	15,075,000	\$ 123,123.13	\$ 97,468.14	\$ 41,383.34	99 Accounts
Nov-17	32,726,000	24,590,352	3,114,111	8,135,648	16,210,000	\$ 117,480.06	\$ 97,274.72	\$ 41,353.12	109 Accounts
Dec-17	27,890,000	20,997,080	2,934,207	6,892,920	16,300,000	\$ 111,910.99	\$ 96,813.74	\$ 41,366.31	126 Accounts
Jan-18	26,401,000	18,635,282	1,094,161	7,765,718	17,091,000	\$ 111,110.99	\$ 96,740.13	\$ 41,705.81	140 Accounts
Feb-18	25,603,000	19,111,115	1,067,208	5,424,677	16,480,000	\$ 110,395.28	\$ 97,142.70	\$ 41,731.98	140 Accounts
Mar-18	25,024,000	18,850,501	705,755	5,467,744	14,940,000	\$ 111,249.76	\$ 97,600.87	\$ 41,931.66	146 Accounts
Apr-18	29,979,000	23,762,516	991,746	5,224,738	14,089,000	\$ 118,251.28	\$ 97,810.33	\$ 41,922.38	147 Accounts
May-18	29,503,000	33,929,103	2,677,064	-7,103.167	14,051,000	\$ 145,449.23	\$ 99,731.85	\$ 41,892.42	148 Accounts

Totals includes billing for final accounts

To the best of my knowledge, the information is true and correct.

  
 Liz German  
 Office Senior Clerk

6/15/2018  
 Date

## \*\*\*\* TOTALS BY JOB CODE \*\*\*\*

<u>JOB CODE</u>	<u>TOTAL COMPLETED</u>	<u>TOTAL OUTSTANDING</u>	<u>TOTAL NEW</u>	<u>TOTAL PENDING</u>	<u>TOTAL VOID</u>
DIS - DISCONNECT	6	0	0	0	6
CON - CONNECT	3	0	0	0	0
INFO - TEST METER	18	0	0	0	0
OCC - OCCUPANT CHANGE	1	0	0	0	0
ODOR - ODOR (BAD TASTE/SMELL)	2	0	0	0	0
MC - METER CHANGE	2	0	0	0	0
MISC - MISC REPORT	3	0	0	0	0
TEMP - TEMP SHUT OF FOR REPAI	1	0	0	0	0
SWR - SEWER PLUG UP	1	0	0	0	0
HYDRT - HYDRANT LEAK	1	0	0	0	0
LEAK - METER LEAK	1	0	0	0	0
TOTAL ALL CODES	39	0	0	0	6