



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

www.heber.ca.gov

December 12, 2017

Attention: Mrs. Fischer

Subject: November 2017 Monthly Report

On the billing cycles ending on the 22rd of November 30,726,000 gallons of water were used by our consumers, an average of 1,024,000 gallons was used per day.

On November 1, 2017, collected the fourth quarter Trihalomethanes (TTHM's) and Haloacetic Acids (Haa5) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on November 14, 2017 and were once again below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 72 ppb for the Mc Cabe site and 62 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

If you have any questions, please contact me at (760) 427-4685


Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez

Chief Operator

Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

www.heber.ca.gov

December 12, 2017

Attention: Mrs. Fischer
General Manager

Subject: Water Distribution Report November 2017

A) Water breaks (0)

B) Service Leak (3)

1. 139 Mc Cabe Road
2. 75 W. Hawk
3. 1021 Heber Ave

C) Work orders (28)

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Chief Operator
Heber Public Utility District




HEBER PUBLIC UTILITY DISTRICT
Water Treatment Plant and Billing Report
Billing Period : October 22, 2017 thru November 22, 2017

Mth. & Yr.	Water		HPUD Offices / Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced	10% Senior Discount
	Gallons Produced	Gallons Invoiced	Gallons not Invoiced	Water not accounted	Influent	Water	Sewer	Trash	# of Accounts receiving the discount
Nov-16	31,567,000	23,421,593	1,406,582	6,738,825	18,835,000	\$ 119,389.36	\$ 99,269.30	\$ 41,338.80	-
Dec-16	27,591,000	19,384,722	1,344,947	6,861,331	19,332,000	\$ 112,768.91	\$ 99,395.38	\$ 41,406.22	-
Jan-17	22,833,000	14,942,776	686,130	7,204,094	17,310,000	\$ 109,302.03	\$ 99,782.01	\$ 41,439.13	-
Feb-17	24,005,000	16,702,805	795,692	7,302,195	16,965,000	\$ 109,810.20	\$ 99,680.10	\$ 41,251.82	-
Mar-17	27,942,000	19,388,577	944,349	7,609,074	16,325,000	\$ 113,162.10	\$ 99,805.52	\$ 41,293.75	-
Apr-17	32,791,000	24,643,923	1,053,561	7,093,516	14,616,000	\$ 119,605.72	\$ 99,800.29	\$ 41,292.49	-
May-17	37,175,000	26,263,237	1,364,143	9,547,620	14,928,000	\$ 122,488.65	\$ 100,029.46	\$ 41,402.03	-
Jun-17	43,530,000	31,613,609	1,439,099	11,773,292	14,481,000	\$ 133,896.35	\$ 99,862.17	\$ 41,345.46	-
Jul-17	41,907,000	32,289,352	1,497,306	8,120,342	13,402,000	\$ 140,711.94	\$ 97,991.51	\$ 41,664.23	44 accounts
Aug-17	41,160,000	31,401,126	1,659,102	8,099,772	13,570,000	\$ 137,488.33	\$ 98,196.57	\$ 41,576.85	71 accounts
Sep-17	36,291,000	30,248,999	2,067,177	3,974,824	14,380,000	\$ 134,264.75	\$ 98,046.65	\$ 41,602.82	82 accounts
Oct-17	36,098,000	27,671,827	3,021,435	8,426,173	15,075,000	\$ 123,123.13	\$ 97,468.14	\$ 41,383.34	99 accounts
Nov-17	32,726,000	24,590,352	3,114,111	8,135,648	16,210,000	\$ 117,480.06	\$ 97,274.72	\$ 41,353.12	109 accounts

Totals includes billing for final accounts


To the best of my knowledge, the information is true and correct.


 Liz German
 Office Senior Clerk

12/12/17
 Date

**** TOTALS BY JOB CODE ****

JOB CODE	TOTAL COMPLETED	TOTAL OUTSTANDING	TOTAL NEW	TOTAL PENDING	TOTAL VOID
DIS - DISCONNECT	8	0	0	0	6
INFO - TEST METER	10	0	0	0	0
CON - CONNECT	5	0	0	0	0
LEAK - METER LEAK	2	1	0	0	0
OCC - OCCUPANT CHANGE	2	0	0	0	0
WTR - WATER BREAK	1	0	0	0	0
MISC - MISC REPORT	2	1	0	0	0
MC - METER CHANGE	3	0	0	0	0
TOTAL ALL CODES	33	2	0	0	6



Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H
Heber, CA 92249
TEL. (760) 482-2440 • FAX (760) 353-9951
www.heber.ca.gov

December 8, 2017

Attention: Laura Fischer
General Manager

SUBJECT: Heber W.W.T.P. Operations from October 22, 2017 to November 22, 2017

- A. Major violations: (NONE)
- B. Minor violations (NONE)
- C. Major sewer spills (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System: Operating fine. Self Cleaning. No Maintenance.
- F. Vactor Truck:
 - (11/7) Clean up sewer spill at drying beds (3hrs)
 - (11/19) Repair Service line leak at 1021 Heber (6hrs)

- G. From October 22, 2017 through November 22, 2017:
Heber Wastewater Plant received and treated 16.210 MG.

- H. HPUD did not exceed the daily maximum flow (1.2 MGD) as of
November 22, 2017.

Sincerely,

A handwritten signature in blue ink that reads "Lucas G. Agatep".

Lucas G. Agatep
Wastewater Plant Lead Operator

Heber Public Utility District is an equal opportunity provider and employer