

Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H
Heber, CA 92249
TEL. (760) 482-2440 • FAX (760) 353-9951
www.heber.ca.gov

October 8, 2020

Attention: Laura Fischer
General Manager

SUBJECT: Heber W.W.T.P. Operations from August 22, 2020 through September 22, 2020.

- A. Major violations: (ONE) September 16, 2020 a bacteriological sample was collected and it exceeded the instantaneous maximum daily of 400 MPN/100ml for E. Coli and Fecal Coliform. Both E. coli and Fecal Coliform had a result of 540 MPN/100ml.
- B. Minor violations (NONE)
- C. Major sewer spills (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System: Operating fine. Self-cleaning. No maintenance.
- F. Vactor Truck: The vactor truck was not used in this monthly cycle. Maintenance on the vactor truck was performed-screens and filters were changed.
- G. TOTAL OF MILES OF SEWER LINES CLEANED OR VIDEOED: 0 miles.
- H. From August 22, 2019 through September 22, 2019: Heber Wastewater Plant received and treated 14.206 MG.
- I. HPUD did not exceed the daily maximum flow (1.2 MGD) as of September 22, 2020.

Sincerely,

A handwritten signature in blue ink, appearing to be "E. Gonzalez".

Edoardo S. Gonzalez
Wastewater Plant Lead Operator



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

www.heber.ca.gov

October 8, 2020

Attention: Mrs. Fischer

Subject: September 2020 Monthly Report

On the billing cycles ending on the 22rd of September 35,205,000 gallons of water were used by our consumers, an average of 1,135,000 gallons was used per day.

On September 22, 2020 collected third quarter TTHM's samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on September 28, 2020 and were below the maximum contaminant level (MCL) for the both sites. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and for the month of September of 2020 we attained a RAA of 55 ppb for the Mc Cabe Cove site and 45 ppb for the Little Field site. Heber Public Utility District is in compliance with State and Federal water regulations.

On September 22, 2020 replace the chlorine pump motor at the hypochlorite system area. The previous motor had started to rattle and a new motor was installed. A new motor was ordered to have as a back up.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez

Chief Operator

Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

October 8, 2020

Attention: Mrs. Fischer
General Manager

Subject: Water Distribution Report September 2020

A) Water breaks (1)
1. 18 Pheasant Court

B) Service Leak (0)

C) Work orders (68)

MISC - MISC REPORT	2
INFO - TEST METER	18
MC - METER CHANGE	23
FIREF - ENCODER/FIRELY	5
DIS - DISCONNECT	3
CON - CONNECT	6
OCC - OCCUPANT CHANGE	3
LEAK - METER LEAK	6
WTR - WATER BREAK	1
<u>TEMP - TEMP SHUT OF FOR REPAIR</u>	<u>1</u>
TOTAL ALL CODES	68

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Chief Operator
Heber Public Utility District




HEBER PUBLIC UTILITY DISTRICT
Water Treatment Plant and Billing Report
Billing Period : August 22, 2020 thru September 22, 2020

Mth. & Yr.	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced	10% Senior Discount
	Gallons Produced	Gallons Invoiced	Gallons not invoiced	Water not accounted	Influent	Water	Sewer	Trash	# of Accounts receiving the discount
Jul-19	33,877,000	31,217,191	911,330	1,748,479	12,532,000	\$ 150,260.55	\$ 109,394.37	\$ 42,349.93	163 Accounts
Aug-19	38,071,000	32,030,299	1,117,568	4,923,133	13,400,000	\$ 151,758.90	\$ 109,215.84	\$ 42,861.52	163 Accounts
Sep-19	32,729,000	30,102,164	986,371	1,640,465	16,400,000	\$ 143,549.73	\$ 108,749.13	\$ 42,871.19	163 Accounts
Oct-19	31,749,000	29,548,772	890,162	1,310,066	15,500,000	\$ 151,383.50	\$ 108,493.65	\$ 43,023.16	163 Accounts
Nov-19	29,230,000	29,171,891	688,018	-629,909	15,470,000	\$ 166,448.62	\$ 108,248.90	\$ 43,031.40	163 Accounts
Dec-19	15,932,000	18,224,242	1,477,394	-3,769,636	12,960,000	\$ 123,129.60	\$ 108,012.09	\$ 43,038.65	163 Accounts
Jan-20	13,320,000	16,366,111	664,601	-3,710,712	12,600,000	\$ 117,733.83	\$ 107,948.42	\$ 43,057.15	163 Accounts
Feb-20	16,374,000	17,601,700	696,990	-1,924,690	13,286,000	\$ 118,625.33	\$ 108,175.81	\$ 43,034.00	163 Accounts
Mar-20	16,252,000	18,181,251	1,053,102	-2,982,353	16,213,000	\$ 118,006.60	\$ 107,959.71	\$ 43,030.77	163 Accounts
Apr-20	20,885,000	20,544,634	1,440,056	-1,099,690	15,668,000	\$ 120,398.59	\$ 107,968.23	\$ 43,029.59	161 Accounts
May-20	31,112,000	29,476,644	1,768,456	-133,100	13,574,000	\$ 139,256.12	\$ 108,561.05	\$ 43,031.35	161 Accounts
Jun-20	35,167,000	32,582,617	1,427,409	1,156,974	13,519,000	\$ 149,199.04	\$ 108,927.36	\$ 43,063.68	160 Accounts
Jul-20	36,961,000	33,128,171	1,544,429	2,288,400	12,371,000	\$ 153,462.62	\$ 110,697.22	\$ 46,463.62	160 Accounts
Aug-20	38,948,000	35,125,120	1,525,512	2,297,368	13,469,000	\$ 160,702.62	\$ 111,097.04	\$ 45,089.43	160 Accounts
Sep-20	35,205,000	31,572,217	1,236,424	2,396,359	14,206,000	\$ 150,897.30	\$ 110,658.57	\$ 45,043.46	160 Accounts

Totals includes billing for final accounts

To the best of my knowledge, the information is true and correct.


 Liz German
 Office Senior Clerk

10.8.2020
 Date

**** TOTALS BY JOB CODE ****

JOB CODE	TOTAL COMPLETED	TOTAL OUTSTANDING	TOTAL NEW	TOTAL PENDING	TOTAL VOID
MISC - MISC REPORT	2	0	0	0	0
INFO - TEST METER	18	0	0	0	1
MC - METER CHANGE	23	0	0	0	0
FIREF - ENCODER/FIRELY	5	0	0	0	0
DIS - DISCONNECT	3	0	0	0	0
CON - CONNECT	6	0	0	0	0
OCC - OCCUPANT CHANGE	3	0	0	0	0
LEAK - METER LEAK	6	0	0	0	0
WTR - WATER BREAK	1	0	0	0	0
TEMP - TEMP SHUT OF FOR REPAI	1	0	0	0	0
TOTAL ALL CODES	68	0	0	0	1