

Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H
Heber, CA 92249
TEL. (760) 482-2440 • FAX (760) 353-9951
www.heber.ca.gov

June 09, 2016

Attention: Mrs. Fischer

Subject: May 2016 Monthly Report

On the billing cycle ending on the 24th of May 36,109,000 gallons of water were used by our consumers, an average of 1,165,000 gallons was used per day.

On May 11, 2016 the hypochlorite system failed due to an electrical short in the brine pump motor. A new brine motor was ordered from the manufacture. As a result of the hypochlorite system failure and a week out for the new brine motor to be delivered, we purchased 12.5% hypochlorite solution from our local chemical supplier to continue with the disinfection process. On May 17, 2016 brine pump motor was delivered and the operators made the installation. The Hypochlorite system is now in operations. There were no violations because of this incident.

On May 25, 2016 a planned water distribution shut down was required in order to make improvements to the Water Treatment Plant. HPUD was able to maintain a 20 pressure per square inch (psi) throughout the distribution water lines by means of a portable 6 inch pump. After pressure was back to normal, bacteriological samples were taken as per State Water Board Division of Drinking Water requirements and all samples were absent of bacteria. There were no violations due to this water distribution shut down.

If you have any questions, please contact me at (760) 427-4685


Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez", is written over a light blue rectangular background.

Francisco Rodriguez

Chief Operator

Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H
Heber, CA 92249
TEL. (760) 482-2440 • FAX (760) 353-9951
www.heber.ca.gov

June 09, 2016

Attention: Mrs. Fischer
General Manager

Subject: Water Distribution Report May 2016

- A) Water breaks (1)
 - 1. 12 Mallard Ct.


- B) Service Leak (0)

- C) Work orders (49)

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Water Distribution Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H
Heber, CA 92249
TEL. (760) 482-2440 • FAX (760) 353-9951
www.heber.ca.gov

June 13, 2016

Attention: Laura Fischer
General Manager

SUBJECT: Heber W.W.T.P. Operations from April 23, 2016 to
May 24, 2016

- A. Major violations (NONE)
- B. Minor violations (NONE)
- C. Major sewer spills (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System: Operating fine.
- F. Vector Truck: Cleaned raw water wetwell at Water Plant. Cleaned influent channel grit chamber at Wastewater Plant.

- G. From April 23, 2016 through May 24, 2016:
Heber Wastewater Plant received and treated 18.720 MG.

- H. HPUD did not exceed the daily maximum flow (1.2 MGD) as
of May 24, 2016.

Sincerely,

A handwritten signature in blue ink that reads "Lucas G. Agatep".

Lucas G. Agatep
Wastewater Plant Lead Operator