

Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H
Heber, CA 92249
TEL. (760) 482-2440 • FAX (760) 353-9951
www.heber.ca.gov

November 8, 2021

Attention: Laura Fischer
General Manager

SUBJECT: Heber W.W.T.P. Operations from September 21, 2021 through October 21, 2021.

- A. Major violations: (NONE)
- B. Minor violations (NONE)
- C. Major sewer spills (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System: Operating fine. Self-cleaning. No maintenance.
- F. Vector Truck: October 19, 2021 Vector truck was used to expose a water service leak at the Wastewater Treatment Plant.
- G. TOTAL OF MILES OF SEWER LINES CLEANED OR VIDEOED: 0 miles.
- H. From September 21, through October 21, 2021: Heber Wastewater Plant received and treated 14.689 MG.
- I. HPUD did not exceed the daily maximum flow (1.2 MGD) as of October 21, 2021.

Sincerely,

A handwritten signature in blue ink, appearing to be "E. Gonzalez", is written over a faint blue circular stamp.

Edoardo S. Gonzalez
Wastewater Plant Lead Operator

Heber Public Utility District is an equal opportunity provider and employer



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

Nov 8, 2021

Attention: Mrs. Fischer
General Manager

Subject: Water Distribution Report October 2021

A) Water breaks (0)

B) Service Leak (2)

1. 1184 Rockwood Rd.
2. 1180 Heber Ave.

C) Work Orders (41)

LEAK - METER LEAK	5
HYDRT- HYDRANT LEAK	1
WTR - WATER BREAK	0
CON - CONNECT	5
INFO - TEST METER	4
DIS - DISCONNECT	6
OCC - OCCUPANT CHANGE	5
MISC - MISC REPORT	2
MC - METER CHANGE	2
FIREF - ENCODER/FIREFLY	11

TOTAL ALL CODES 41

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

www.heber.ca.gov

Nov 9, 2021

Attention: Mrs. Fischer

Subject: October 2021 Monthly Report

On the billing cycles ending on the 21st of October 26,699,000 gallons of water were used by our consumers, an average of 890,000 gallons was used per day.

On October 13, 2021 collected fourth quarter TTHM's samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on October 26, 2021 and were below the maximum contaminant level (MCL) for the both sites. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and for the 4th of 2021 we attained a RAA of 54 ppb for the Mc Cabe Cove site and 39 ppb for the Little Field site. Heber Public Utility District is in compliance with State and Federal water regulations.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez

Chief Operator

Heber Public Utility District




HEBER PUBLIC UTILITY DISTRICT
Water Treatment Plant and Billing Report
Billing Period : September 21 thru October 21, 2021

Month & Year	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced	10% Senior Discount
	Gallons Produced	Gallons Invoiced	Gallons not invoiced	Water not accounted	Influent	Water	Sewer	Trash	# of Accounts receiving the discount
Sep-20	35,205,000	31,572,217	1,236,424	2,396,359	14,206,000	\$ 150,897.30	\$ 110,658.57	\$ 45,043.46	160 Accounts
Oct-20	29,736,000	28,237,222	1,173,394	325,384	14,080,000	\$ 142,382.65	\$ 110,585.55	\$ 45,073.63	160 Accounts
Nov-20	24,564,000	24,494,089	971,635	-901,724	15,691,000	\$ 134,470.92	\$ 110,411.04	\$ 45,041.17	160 Accounts
Dec-20	18,680,000	20,253,241	1,056,457	-1,574,297	15,677,000	\$ 125,254.29	\$ 110,132.85	\$ 45,054.58	160 Accounts
Jan-21	16,473,000	18,875,235	681,311	-3,083,546	14,754,000	\$ 123,891.35	\$ 109,965.78	\$ 45,057.20	160 Accounts
Feb-21	15,014,000	18,248,193	1,376,752	-4,610,945	15,594,000	\$ 122,286.91	\$ 109,939.30	\$ 45,053.65	160 Accounts
Mar-21	20,140,000	20,543,021	1,246.92	-404,268	15,217,000	\$ 126,486.28	\$ 109,795.58	\$ 45,059.21	160 Accounts
Apr-21	24,574,000	24,794,856	990,442	-1,211,298	13,643,000	\$ 135,105.68	\$ 110,199.26	\$ 45,062.13	160 Accounts
May-21	29,069,000	29,006,809	1,118,659	-1,056,468	13,493,000	\$ 145,296.68	\$ 110,644.57	\$ 45,103.11	160 Accounts
Jun-21	34,058,000	31,475,053	995,996	1,586,951	12,759,000	\$ 153,480.20	\$ 110,853.62	\$ 45,093.07	160 Accounts
Jul-21	34,935,000	32,154,122	1,290,395	1,490,483	12,615,000	\$ 158,410.60	\$ 114,764.18	\$ 45,748.42	160 Accounts
Aug-21	32,417,000	31,453,355	1,268,417	-304,772	12,911,000	\$ 157,163.81	\$ 114,560.14	\$ 45,832.97	160 Accounts
Sep-21	31,654,000	28,342,655	857,001	2,454,344	13,754,000	\$ 148,985.35	\$ 114,671.34	\$ 45,845.12	160 Accounts
Oct-21	26,699,000	26,795,989	1,218,529	-1,315,518	14,689,000	\$ 144,779.02	\$ 114,807.45	\$ 45,876.06	160 Accounts

Totals includes billing for final accounts

To the best of my knowledge, the information is true and correct.


 Liz German
 Office Senior Clerk

11/8/21
 Date

**** TOTALS BY JOB CODE ****

<u>JOB CODE</u>	<u>TOTAL COMPLETED</u>	<u>TOTAL OUTSTANDING</u>	<u>TOTAL NEW</u>	<u>TOTAL PENDING</u>	<u>TOTAL VOID</u>
DIS - DISCONNECT	6	0	0	0	0
MC - METER CHANGE	2	3	0	0	0
CON - CONNECT	5	0	0	0	0
OCC - OCCUPANT CHANGE	5	0	0	0	0
FIREF - ENCODER/FIRELY	11	4	0	0	0
LEAK - METER LEAK	5	1	3	0	1
INFO - TEST METER	4	2	1	0	0
MISC - MISC REPORT	2	0	0	0	0
HYDRT - HYDRANT LEAK	1	0	0	0	0
WTR - WATER BREAK	0	1	0	0	0
TOTAL ALL CODES	41	11	4	0	1