



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

May 3, 2024

Attention: Madeline  
General Manager

Subject: April 2024 Monthly Report

On the billing cycle ending on the 22nd of April 25,549,000 gallons of water were used by our consumers, an average of 798,000 gallons was used per day.

On April 17, 2024, collected Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on April 29, 2024 and were below the running annual average (RAA) MCL the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 59 ppb for the Mc Cabe site and 46 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

If you have any questions, please contact me at (760) 427-4685.


Respectfully,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez

Chief Operator

Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

May 3, 2024

Attention: Madeline  
General Manager

Subject: Water Distribution Report April 2024

- a) Water breaks (1)
  - 1. 71 10<sup>th</sup> Street
  
- b) Service Leak (4)
  - 1. 71 9<sup>TH</sup> Street
  - 2. 57 10<sup>TH</sup> Street
  - 3. 68 10<sup>th</sup> Street
  - 4. 73 10<sup>th</sup> Street

c) Work orders (85)


Total Outstanding

LEAK - METER LEAK-----	7	0
DIS - DISCONNECT-----	8	0
CON - CONNECT-----	4	0
INFO - TEST METER -----	1	0
MC - METER CHANGE-----	21	4
OCC - OCCUPANT CHANGE-----	3	0
MISC-MISC REPORT-----	4	0
FIREF - ENCODER/FIREFLY-----	29	10
TEST WATER PRESSURE-----	1	0
WTR - SERVICE LINE LEAK-----	3	0
TEMP - TEMP SHUT OFF VALVE-----	2	0
HYDRT - HYDRANT LEAK-----	2	0
VALVE - REPLACE SHUT OFF VALVE---	0	1
<b>TOTAL ALL CODES</b>	<b>85</b>	<b>15</b>

Respectfully,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez  
Water Chief Operator  
Heber Public Utility District



## Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H  
Heber, CA 92249  
TEL. (760) 482-2440 • FAX (760) 353-9951  
www.heber.ca.gov

May 9, 2024

Attention: Madeline Dessert  
General Manager

SUBJECT: Heber W.W.T.P. Operations from March 21, 2024 through April 22, 2024.

- A. Major violations: (NONE)
- B. Minor violations: (NONE)
- C. Major sewer spills: (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System: Operating fine. Self-cleaning.
- F. Vactor Truck: Vactor truck was used on April 4, and April 5, 2024 for service leaks on 10<sup>th</sup> st.
- G. TOTAL OF MILES OF SEWER LINES CLEANED OR VIDEOED: 0 miles.
- H. From March 21, 2024 through April 22, 2024: Heber Wastewater Plant received and treated 16.037 MG.
- I. HPUD did not exceed the daily maximum flow (1.2 MGD) as of April 22, 2024.

Sincerely,

A handwritten signature in blue ink, appearing to be "E. Gonzalez".

Edoardo S. Gonzalez  
Wastewater Plant Lead Operator



HEBER PUBLIC UTILITY DISTRICT

Water & Wastewater Treatment Plants and Billing Report  
 Billing Period : March 21, 2024 THRU April 22, 2024

Month & Year	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced	10% Senior Discount
	Gallons Produced	Gallons Invoiced	Gallons not invoiced	Water not accounted	Influent	Water	Sewer	Trash	# of Accounts receiving the discount
Apr-23	19,578,000	23,851,240	2,467,680	-6,740,920	13,959,000	\$ 137,270.06	\$ 116,752.65	\$ 54,129.28	160 Accounts
May-23	24,937,000	27,283,599	2,091,376	-4,437,975	13,429,000	\$ 145,124.77	\$ 116,710.16	\$ 54,054.90	160 Accounts
Jun-23	28,781,000	29,925,186	2,454,108	-3,598,294	14,212,000	\$ 149,604.48	\$ 117,451.77	\$ 54,154.44	160 Accounts
Jul-23	30,540,000	33,019,108	2,481,826	-4,960,934	12,877,000	\$ 158,940.92	\$ 117,756.38	\$ 55,755.67	160 Accounts
Aug-23	31,134,000	29,923,590	2,513,664	-1,303,254	13,991,000	\$ 150,960.04	\$ 117,671.85	\$ 55,810.93	160 Accounts
Sep-23	34,405,000	27,531,530	2,616,579	4,256,891	13,723,000	\$ 143,774.19	\$ 117,357.33	\$ 55,767.32	160 Accounts
Oct-23	30,110,000	27,412,985	2,231,252	465,763	14,544,000	\$ 144,521.19	\$ 117,579.77	\$ 55,759.60	160 Accounts
Nov-23	24,697,000	23,117,991	1,764,615	-185,606	15,743,000	\$ 137,195.23	\$ 117,267.22	\$ 55,685.68	160 Accounts
Dec-23	20,976,000	21,708,288	2,543,739	-3,276,027	14,691,000	\$ 135,839.85	\$ 116,781.70	\$ 55,576.30	160 Accounts
Jan-24	20,638,366	18,135,000	1,825,771	677,595	15,560,000	\$ 134,297.40	\$ 117,302.21	\$ 55,426.19	160 Accounts
Feb-24	15,667,000	16,178,248	2,054,462	-2,565,710	17,779,000	\$ 124,392.83	\$ 116,000.69	\$ 55,382.61	160 Accounts
Mar-24	20,322,000	21,108,650	1,837,250	-2,623,900	16,197,000	\$ 129,995.46	\$ 116,490.45	\$ 56,706.82	160 Accounts
<b>Apr-24</b>	<b>25,549,000</b>	<b>24,474,159</b>	<b>2,026,456</b>	<b>-951,615</b>	<b>16,037,000</b>	<b>\$ 137,142.31</b>	<b>\$ 116,538.21</b>	<b>\$ 57,140.44</b>	<b>159 Accounts</b>

Totals includes billing for final accounts  
 To the best of my knowledge, the information is true and correct.

*Liz German*  
 Liz German  
 Office Senior Clerk

5/09/2024  
 Date

## \*\*\*\* TOTALS BY JOB CODE \*\*\*\*

JOB CODE	TOTAL COMPLETED	TOTAL OUTSTANDING	TOTAL NEW	TOTAL PENDING	TOTAL VOID
DIS - DISCONNECT	8	0	0	0	16
MISC - MISC REPORT	4	0	0	0	0
LEAK - METER LEAK	7	0	0	0	0
MC - METER CHANGE	21	4	0	0	0
CON - CONNECT	4	0	0	0	0
WTR - SERVICE LINE LEAK	3	0	0	0	0
PRSUR - TEST WATER PRESSURE	1	0	0	0	0
OCC - OCCUPANT CHANGE	3	0	0	0	0
TEMP - TEMP SHUT OF FOR REPAI	2	0	0	0	0
FIREF - ENCODER/FIRELY	29	10	0	0	0
HYDRT - HYDRANT LEAK	2	0	0	0	0
INFO - TEST METER	1	0	0	0	0
VALVE - REPLACE SHUT OF VALVE	0	1	0	0	0
TOTAL ALL CODES	85	15	0	0	16