



## Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H  
Heber, CA 92249  
TEL. (760) 482-2440 • FAX (760) 353-9951  
[www.heber.ca.gov](http://www.heber.ca.gov)

May 8, 2014

Attention: Mrs. Fischer

Subject: April 2014 Monthly Report

On the billing cycle ending on the 25<sup>th</sup> of April 36,590,000 gallons of water were used by our consumers, an average of 1,180,322 gallons was used per day.

On April 23, 2014 received a call from Imperial County Lab notifying us that one of our routine bacteriological samples resulted positive with coliform, which is an indication of possible bacteria contamination. After repeat samples were taken from original site and upstream and downstream as required by the California Department of Public Health (CDPH), results came back absent, meaning no bacteria was present. I informed Mr. Scott Ketcham from CDPH and no further action is required other than reporting results in the Monthly Monitoring Report to CDPH. The day the samples were taken it was windy and is probably the cause of the sample contamination leading to a positive bacteriological result.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District



## Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H

Heber, CA 92249

TEL. (760) 482-2440 • FAX (760) 353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

May 8, 2014

Attention: Mrs. Fischer  
General Manager

Subject: Water Distribution Report April 2014

a) Water breaks (0)

b) Service Leak (2)

1. 55 10<sup>th</sup> Street
2. 29 Mc Cabe Road

c) Work orders ( 36 )

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez  
Water Distribution Chief Operator  
Heber Public Utility District



**HEBER PUBLIC UTILITY DISTRICT**  
**Water Treatment Plant and Billing Report**  
**Billing Period : March 26, 2014 thru April 25, 2014**

	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced
Mth. & Yr.	Gals. Produced	Gals. Invoiced	Gallons not invoiced	Not accounted	Influent	Water	Sewer	Trash
Mar-13	31,877,000	20,435,491	778,060	10,663,449	20,051,000	\$ 106,536.72	\$ 93,320.33	\$ 40,254.68
Apr-13	35,296,000	24,541,981	985,680	9,768,339	19,340,000	\$ 109,825.86	\$ 93,106.22	\$ 40,537.26
May-13	41,142,000	28,553,743	1,360,150	11,228,107	18,865,000	\$ 116,271.41	\$ 93,339.42	\$ 40,404.40
Jun-13	47,667,000	32,253,849	964,130	14,449,021	18,054,000	\$ 125,644.21	\$ 93,324.96	\$ 40,232.02
Jul-13	47,035,000	31,272,209	750,132	15,012,659	17,207,000	\$ 129,449.72	\$ 98,707.73	\$ 40,254.33
Aug-13	48,345,000	35,408,520	1,062,559	11,873,921	17,751,000	\$ 133,639.01	\$ 98,565.91	\$ 40,159.80
Sep-13	35,871,000	23,104,479	1,374,987	11,391,534	18,916,000	\$ 114,910.80	\$ 98,469.56	\$ 40,306.66
Oct-13	37,221,000	26,055,914	68,510	11,096,576	18,492,000	\$ 120,239.26	\$ 98,774.93	\$ 40,210.32
Nov-13	31,983,000	22,843,811	493,150	8,646,039	18,441,000	\$ 117,858.18	\$ 98,532.55	\$ 40,137.03
Dec-13	28,235,000	18,661,645	610,850	8,962,505	21,376,000	\$ 110,106.00	\$ 98,623.36	\$ 40,220.16
Jan-14	26,368,000	17,308,692	440,900	8,618,408	18,932,000	\$ 109,125.53	\$ 98,843.20	\$ 40,288.43
Feb-14	30,662,000	19,676,203	506,300	10,479,497	20,406,000	\$ 110,872.63	\$ 98,784.11	\$ 40,212.37
Mar-14	30,470,000	19,739,013	48,225	10,682,762	18,311,000	\$ 110,650.31	\$ 98,772.35	\$ 40,207.46
<b>Apr-14</b>	<b>36,590,000</b>	<b>24,899,285</b>	<b>415,770</b>	<b>11,274,945</b>	<b>17,856,000</b>	<b>\$ 120,326.04</b>	<b>\$ 98,908.54</b>	<b>\$ 40,341.65</b>
Totals includes billing for final accounts								

To the best of my knowledge, the information is true and correct.

*Liz German*  
 Liz German  
 Office Senior Clerk

*5/9/14*  
 Date

April 2014



## Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H

Heber, CA 92249

TEL. (760) 482-2440 • FAX (760) 353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

May 9, 2014

Attention: Laura Fischer  
General Manager

SUBJECT: Heber W.W.T.P. Operations from March 26, 2014 to  
April 25, 2014

- A. Major violations (NONE)
- B. Minor violations (NONE)
- C. Major sewer spills (NONE)
- D. Main sewer Plugs (ONE) Alley between Main St. and Crane St.
- E. UV System working fine, no problems.
- F. From March 26, 2014 through April 25, 2014:  
Heber Wastewater Plant received and treated 17.856 MG.
- G. HPUD did not exceed the daily maximum flow (1.2 MGD) as  
of April 25, 2014.

Sincerely,

A handwritten signature in black ink, appearing to be "E. Gonzalez", written over a light blue horizontal line.

Edoardo S. Gonzalez  
Wastewater Plant Operator