

Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H

Heber, CA 92249

TEL. (760) 482-2440 • FAX (760) 353-9951

www.heber.ca.gov

June 11, 2014

Attention: Mrs. Fischer

Subject: May 2014 Monthly Report

On the billing cycle ending on the 26th of May 42,251,000 gallons of water were used by our consumers, an average of 1,320,344 gallons was used per day.

On June 27, 2014 due to the County accidentally breaking off a fire hydrant at the corner of Pitzer and Correll Road water pressure dropped throughout the water distribution system. The valve to the fire hydrant was immediately closed off restoring water pressure to normal within twenty minutes. There were no violations due to this incident. There were approximately ten customer complain due to this incident. A hydrant and material needed to replace the hydrant has been ordered. The County will be billed for labor and material for the replacement of the fire hydrant.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez

Chief Operator

Heber Public Utility District



HEBER PUBLIC UTILITY DISTRICT

Water Treatment Plant and Billing Report

Billing Period : April 25, 2014 thru May 26, 2014


Mth. & Yr.	Water		HPUD Offices / Parks Gallons not invoiced	Difference Water Not accounted	Sewer		Invoiced Water	Invoiced Sewer	Invoiced	
	Gals. Produced	Gals. Invoiced			Influent				Water	Trash
Apr-13	35,296,000	24,541,981	985,680	9,768,339	19,340,000		\$ 109,825.86	\$ 93,106.22	\$	\$ 40,537.26
May-13	41,142,000	28,553,743	1,360,150	11,228,107	18,865,000		\$ 116,271.41	\$ 93,339.42	\$	\$ 40,404.40
Jun-13	47,667,000	32,253,849	964,130	14,449,021	18,054,000		\$ 125,644.21	\$ 93,324.96	\$	\$ 40,232.02
Jul-13	47,035,000	31,272,209	750,132	15,012,659	17,207,000		\$ 129,449.72	\$ 98,707.73	\$	\$ 40,254.33
Aug-13	48,345,000	35,408,520	1,062,559	11,873,921	17,751,000		\$ 133,639.01	\$ 98,565.91	\$	\$ 40,159.80
Sep-13	35,871,000	23,104,479	1,374,987	11,391,534	18,916,000		\$ 114,910.80	\$ 98,469.56	\$	\$ 40,306.66
Oct-13	37,221,000	26,055,914	68,510	11,096,576	18,492,000		\$ 120,239.26	\$ 98,774.93	\$	\$ 40,210.32
Nov-13	31,983,000	22,843,811	493,150	8,646,039	18,441,000		\$ 117,858.18	\$ 98,532.55	\$	\$ 40,137.03
Dec-13	28,235,000	18,661,645	610,850	8,962,505	21,376,000		\$ 110,106.00	\$ 98,623.36	\$	\$ 40,220.16
Jan-14	26,368,000	17,308,692	440,900	8,618,408	18,932,000		\$ 109,125.53	\$ 98,843.20	\$	\$ 40,288.43
Feb-14	30,662,000	19,676,203	506,300	10,479,497	20,406,000		\$ 110,872.63	\$ 98,784.11	\$	\$ 40,212.37
Mar-14	30,470,000	19,739,013	48,225	10,682,762	18,311,000		\$ 110,650.31	\$ 98,772.35	\$	\$ 40,207.46
Apr-14	36,590,000	24,899,285	415,770	11,274,945	17,856,000		\$ 120,326.04	\$ 98,908.54	\$	\$ 40,341.65
May-14	42,251,000	28,079,149	541,610	13,630,241	18,786,000		\$ 124,318.35	\$ 99,011.19	\$	\$ 40,381.38

Totals includes billing for final accounts

To the best of my knowledge, the information is true and correct.

Liz German
Liz German
Office Senior Clerk

6-10-14
Date



Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H

Heber, CA 92249

TEL. (760) 482-2440 • FAX (760) 353-9951

www.heber.ca.gov

June 11, 2014

Attention: Mrs. Fischer
General Manager

Subject: Water Distribution Report May 2014

A) Water breaks (1)

1. Intersection of Pitzer and Correll Road
(County accidently damaged fire hydrant)

B) Service Leak (1)

1. 1117 Heffernan Ave

C) Work orders (33)

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Water Distribution Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H

Heber, CA 92249

TEL. (760) 482-2440 • FAX (760) 353-9951

www.heber.ca.gov

June 6, 2014

Attention: Laura Fischer
General Manager

SUBJECT: Heber W.W.T.P. Operations from April 25, 2014 to
May 26, 2014

- A. Major violations (NONE)
- B. Minor violations (NONE)
- C. Major sewer spills (NONE)
- D. Main sewer Plugs (NONE)

- E. UV System working fine, no problems.

- F. From April 25, 2014 through May 26, 2014:
Heber Wastewater Plant received and treated 18.786 MG.

- G. HPUD did not exceed the daily maximum flow (1.2 MGD) as
of May 26, 2014.

Sincerely,

A handwritten signature in black ink, appearing to be "E. Gonzalez", written over a light blue horizontal line.

Edoardo S. Gonzalez
Wastewater Plant Operator

Heber Public Utility District is an equal opportunity provider and employer