



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H
Heber CA 92249
Tel:(760)482-2440 • Fax (760)353-9951
www.heber.ca.gov

October 12, 2021

Attention: Mrs. Fischer

Subject: September 2021 Monthly Report

On the billing cycles ending on the 21st of September 31,654,000 gallons of water were used by our consumers, an average of 1,273,000 gallons was used per day.

On September 15, 2021 collected third quarter TTHM's samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on September 27, 2021 and were below the maximum contaminant level (MCL) for the both sites. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and for the month of September of 2021 we attained a RAA of 55 ppb for the Mc Cabe Cove site and 42 ppb for the Little Field site. Heber Public Utility District is in compliance with State and Federal water regulations.

On October 1, 2021 notice an expansion joint in deteriorating conditions at the water distribution outlet. The expansion joint is used in order for the ductile iron pipes have some movement and prevents the pipes from breaking in an event of an earthquake. A new expansion joint has been ordered and will be installed as soon as it is delivered. The replacement of this expansion joint will be at night as it will require to turn off the distribution pumps and the use of a six-inch pump to keep an adequate water distribution pressure.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

October 12, 2021

Attention: Mrs. Fischer
General Manager

Subject: Water Distribution Report September 2021

A) Water breaks (1)
1. 74 11th Street

B) Service Leak (0)

C) Work orders (56)

MISC - MISC REPORT	4
INFO - TEST METER	8
MC - METER CHANGE	8
FIREF - ENCODER/FIRELY	13
DIS - DISCONNECT	3
CON - CONNECT	5
OCC - OCCUPANT CHANGE	2
LEAK - METER LEAK	6
WTR - WATER BREAK	1
SC SERVICE CHANGE	6
<hr/>	
TOTAL ALL CODES	56

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Chief Operator
Heber Public Utility District




HEBER PUBLIC UTILITY DISTRICT

Water Treatment Plant and Billing Report
 Billing Period : August 21 thru September 21, 2021

Month & Year	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced	10% Senior Discount
	Gallons Produced	Gallons Invoiced	Gallons not invoiced	Water not accounted	Influent	Water	Sewer	Trash	# of Accounts receiving the discount
Aug-20	38,948,000	35,125,120	1,525,512	2,297,368	13,469,000	\$ 160,702.62	\$ 111,097.04	\$ 45,089.43	160 Accounts
Sep-20	35,205,000	31,572,217	1,236,424	2,396,359	14,206,000	\$ 150,897.30	\$ 110,658.57	\$ 45,043.46	160 Accounts
Oct-20	29,736,000	28,237,222	1,173,394	325,384	14,080,000	\$ 142,382.65	\$ 110,585.55	\$ 45,073.63	160 Accounts
Nov-20	24,564,000	24,494,089	971,635	-901,724	15,691,000	\$ 134,470.92	\$ 110,411.04	\$ 45,041.17	160 Accounts
Dec-20	18,680,000	20,253,241	1,056,457	-1,574,297	15,677,000	\$ 125,254.29	\$ 110,132.85	\$ 45,054.58	160 Accounts
Jan-21	16,473,000	18,875,235	681,311	-3,083,546	14,754,000	\$ 123,891.35	\$ 109,965.78	\$ 45,057.20	160 Accounts
Feb-21	15,014,000	18,248,193	1,376,752	-4,610,945	15,594,000	\$ 122,286.91	\$ 109,939.30	\$ 45,053.65	160 Accounts
Mar-21	20,140,000	20,543,021	1,246.92	-404,268	15,217,000	\$ 126,486.28	\$ 109,795.58	\$ 45,059.21	160 Accounts
Apr-21	24,574,000	24,794,856	990,442	-1,211,298	13,643,000	\$ 135,105.68	\$ 110,199.26	\$ 45,062.13	160 Accounts
May-21	29,069,000	29,006,809	1,118,659	-1,056,468	13,493,000	\$ 145,296.68	\$ 110,644.57	\$ 45,103.11	160 Accounts
Jun-21	34,058,000	31,475,053	995,996	1,586,951	12,759,000	\$ 153,480.20	\$ 110,853.62	\$ 45,093.07	160 Accounts
Jul-21	34,935,000	32,154,122	1,290,395	1,490,483	12,615,000	\$ 158,410.60	\$ 114,764.18	\$ 45,748.42	160 Accounts
Aug-21	32,417,000	31,453,355	1,268,417	-304,772	12,911,000	\$ 157,163.81	\$ 114,560.14	\$ 45,832.97	160 Accounts
Sep-21	31,654,000	28,342,655	857,001	2,454,344	13,754,000	\$ 148,985.35	\$ 114,671.34	\$ 45,845.12	160 Accounts

Totals includes billing for final accounts


To the best of my knowledge, the information is true and correct.


 Liz German
 Office Senior Clerk

10/5/21
 Date

**** TOTALS BY JOB CODE ****

<u>JOB CODE</u>	<u>TOTAL COMPLETED</u>	<u>TOTAL OUTSTANDING</u>	<u>TOTAL NEW</u>	<u>TOTAL PENDING</u>	<u>TOTAL VOID</u>
DIS - DISCONNECT	3	0	0	0	0
CON - CONNECT	5	0	0	0	0
INFO - TEST METER	8	0	0	0	0
OCC - OCCUPANT CHANGE	2	0	0	0	0
MISC - MISC REPORT	4	0	0	0	0
LEAK - METER LEAK	6	0	0	0	0
MC - METER CHANGE	8	0	0	0	0
WTR - WATER BREAK	1	0	0	0	0
FIREF - ENCODER/FIRELY	13	0	0	0	0
SC - SERVICE CHANGE	6	0	0	0	0
TOTAL ALL CODES	56	0	0	0	0



Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H
Heber, CA 92249

TEL. (760) 482-2440 • FAX (760) 353-9951

www.heber.ca.gov

October 5, 2021

Attention: Laura Fischer
General Manager

SUBJECT: Heber W.W.T.P. Operations from August 21, 2021 through September 21, 2021.

- A. Major violations: (NONE)
- B. Minor violations (NONE)
- C. Major sewer spills (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System: Operating fine. Self-cleaning. No maintenance.
- F. Vactor Truck: September 15, 16, and 17 vactor truck was used to clean out STM aerotor train number one.
- G. TOTAL OF MILES OF SEWER LINES CLEANED OR VIDEOED: 0 miles.
- H. From August 21, 2021 through September 21, 2021: Heber Wastewater Plant received and treated 13.754 MG.
- I. HPUD did not exceed the daily maximum flow (1.2 MGD) as of September 21, 2021.

Sincerely,

A handwritten signature in blue ink, appearing to be "E. Gonzalez", is written over a faint, illegible printed name.

Edoardo S. Gonzalez
Wastewater Plant Lead Operator