

## Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H  
Heber, CA 92249

TEL. (760) 482-2440 • FAX (760) 353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

July 13, 2022

Attention: Laura Fischer  
General Manager

SUBJECT: Heber W.W.T.P. Operations from May 23, 2022 through June 23, 2022.

- A. Major violations: (NONE)
- B. Minor violations (NONE)
- C. Major sewer spills (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System: Operating fine. Self-cleaning.
- F. Vactor Truck: June 3, 2022 vactor truck was utilized for clearing activated sludge line between the West Oxidation Ditch and the Splitter Box going into the clarifier. June 7 and June 8, 2022 the vactor truck was used to drain the South Aerotor basin.
- G. TOTAL OF MILES OF SEWER LINES CLEANED OR VIDEOED: 0 miles.
- H. From May 23, 2022 through June 23, 2022: Heber Wastewater Plant received and treated 13.710 MG.
- I. HPUD did not exceed the daily maximum flow (1.2 MGD) as of June 23, 2022.

Sincerely,

A handwritten signature in blue ink, appearing to be "E. Gonzalez".

Edoardo S. Gonzalez  
Wastewater Plant Lead Operator



**HEBER PUBLIC UTILITY DISTRICT**  
**Water Treatment Plant and Billing Report**  
**Billing Period : May 23, 2022 thru June 23, 2022**

Month & Year	Water		HPUD Offices/Parks	Difference Water	Sewer		Invoiced Water	Invoiced Sewer	Invoiced		10% Senior Discount
	Gallons Produced	Gallons Invoiced			Influent	Water not accounted			Water	Sewer	
May-21	29,069,000	29,006,809	1,118,659	-1,056,468	13,493,000	\$ 145,296.68	\$ 110,644.57	\$ 45,103.11	160 Accounts		
Jun-21	34,058,000	31,475,053	995,996	1,586,951	12,759,000	\$ 153,480.20	\$ 110,853.62	\$ 45,093.07	160 Accounts		
Jul-21	34,935,000	32,154,122	1,290,395	1,490,483	12,615,000	\$ 158,410.60	\$ 114,764.18	\$ 45,748.42	160 Accounts		
Aug-21	32,417,000	31,453,355	1,268,417	-304,772	12,911,000	\$ 157,163.81	\$ 114,560.14	\$ 45,832.97	160 Accounts		
Sep-21	31,654,000	28,342,655	857,001	2,454,344	13,754,000	\$ 148,985.35	\$ 114,671.34	\$ 45,845.12	160 Accounts		
Oct-21	26,699,000	26,795,989	1,218,529	-1,315,518	14,689,000	\$ 144,779.02	\$ 114,807.45	\$ 45,876.06	160 Accounts		
Nov-21	24,333,000	23,580,404	1,765,197	-1,012,601	16,010,000	\$ 136,119.65	\$ 114,442.84	\$ 45,856.37	160 Accounts		
Dec-21	19,724,000	20,187,829	950,258	-1,414,087	16,104,000	\$ 132,319.28	\$ 116,557.96	\$ 46,037.10	166 Accounts		
Jan-22	16,643,000	18,854,458	1,283,504	-3,494,962	16,212,000	\$ 129,211.25	\$ 114,261.22	\$ 45,956.15	166 Accounts		
Feb-22	17,603,000	19,701,325	1,027,964	-3,126,289	15,825,000	\$ 129,295.34	\$ 114,347.62	\$ 46,170.92	166 Accounts		
Mar-22	20,120,000	21,478,091	1,070,163	-2,428,254	14,809,000	\$ 133,718.26	\$ 114,481.67	\$ 46,127.89	166 Accounts		
Apr-22	24,843,000	25,717,812	1,126,185	-2,000,997	14,189,000	\$ 142,277.55	\$ 115,331.18	\$ 46,182.10	166 Accounts		
May-22	28,036,000	26,851,456	1,623,013	-438,469	14,344,000	\$ 143,601.07	\$ 115,552.14	\$ 47,892.08	166 Accounts		
<b>Jun-22</b>	<b>34,243,000</b>	<b>30,933,603</b>	<b>1,417,527</b>	<b>1,891,870</b>	<b>13,710,000</b>	<b>\$ 155,849.02</b>	<b>\$ 115,946.80</b>	<b>\$ 47,793.24</b>	<b>166 Accounts</b>		

Totals includes billing for final accounts  
 To the best of my knowledge, the information is true and correct.

*Liz German*  
 Liz German  
 Office Senior Clerk

7.14.2022  
 Date

## \*\*\*\* TOTALS BY JOB CODE \*\*\*\*

JOB CODE	TOTAL COMPLETED	TOTAL OUTSTANDING	TOTAL NEW	TOTAL PENDING	TOTAL VOID
HYDRT -- HYDRANT LEAK	1	0	0	0	0
DIS -- DISCONNECT	6	0	0	0	5
MISC -- MISC REPORT	4	1	0	0	0
OCC -- OCCUPANT CHANGE	3	0	0	0	0
CON -- CONNECT	5	0	0	0	0
ODOR -- ODOR (BAD TASTE/SMELL)	1	0	0	0	0
ONCAL -- ONCALL OPERATOR WAS CA	1	0	0	0	0
INFO -- TEST METER	4	0	0	0	0
LEAK -- METER LEAK	7	0	0	0	0
MC -- METER CHANGE	0	2	0	0	0
SC -- SERVICE CHANGE	1	0	0	0	0
WTR -- WATER BREAK	2	0	0	0	0
TOTAL ALL CODES	35	3	0	0	5



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H  
Heber CA 92249  
Tel:(760)482-2440 • Fax (760)353-9951  
[www.heber.ca.gov](http://www.heber.ca.gov)

February 10, 2022

Attention: Mrs. Fischer

Subject: January 2022 Monthly Report

On the billing cycle ending on the 21<sup>ST</sup> of January 16,643,000 million gallons of water were used by our consumers, an average of 537,000 thousand gallons was used per day.


On January 20, 2022, collected the 1<sup>st</sup> quarter Trihalomethanes (TTHM's) and Haloacetic Acids (Haa5) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on February 1, 2022 and were once again below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 55 ppb for the Mc Cabe site and 42 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

After further review of the water filter #1 under drains it was recommended by the manufacture to remove and replace all the under drains. Currently, we have acquired two quotes to complete the rehab on this filter and waiting for a third quote. Additionally, after removing the under drains if corrosion is present this will result in added cost to recoat the filter.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

March 3, 2022

Attention: Mrs. Fischer

Subject: February 2022 Monthly Report

On the billing cycle ending on the 21st of February 17,603,000 million gallons of water were used by our consumers, an average of 567,000 thousand gallons was used per day.

On February 16, 2022, collected Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on February 28, 2022 and were once again below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 54 ppb for the McCabe site and 42 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.


If you have any questions, please contact me at (760) 427-4685

Respectfully,

Francisco Rodriguez

Chief Operator

Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

April 7, 2022

Attention: Mrs. Fischer

Subject: March 2022 Monthly Report


On the billing cycle ending on the 23rd of March 20,120,000 gallons of water were used by our consumers, an average of 670,000 gallons was used per day.

On March 17, 2022, collected Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on March 30, 2022 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 55 ppb for the Mc Cabe site and 42 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

If you have any questions, please contact me at (760) 427-4685

Respectfully,

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H  
Heber CA 92249  
Tel:(760)482-2440 • Fax (760)353-9951  
[www.heber.ca.gov](http://www.heber.ca.gov)

May 10, 2022

Attention: Mrs. Fischer

Subject: April 2022 Monthly Report

On the billing cycle ending on the 23rd of April 24,843,000 gallons of water were used by our consumers, an average of 801,000 gallons was used per day.

On April 21, 2022, collected Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on May 2, 2022 and were below the running annual average (RAA) MCL the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 65 ppb for the Mc Cabe site and 46 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.


On April 18, 2022, Operator noticed a chemical spill on the static mixer station. Most of the chemical was confined within the chemical concrete pad containment. Some chemical went outside the HPUD water plant facility and was barricaded to prevent exposure to people. EFR Environmental Services was immediately contracted to clean up and properly dispose of chemical Spill.

On April 22, 2022 received an alarm of backwash pump failure. The backwash pump is used to clean the water filters. Upon inspection the pump had ceased and was placed offline. Currently, we have a second pump which is functional and have ordered the parts to have it refurbish. The pump should be installed and operational by the end of May 2022.

If you have any questions, please contact me at (760) 427-4685.

Respectfully,

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

June 07, 2022

Attention: Mrs. Fischer

Subject: May 2022 Monthly Report

On the billing cycle ending on the 22<sup>rd</sup> of May 28,036,000 gallons of water were used by our consumers, an average of 935,000 gallons was used per day.

On May 19, 2022, collected Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on June 1, 2022 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 60 ppb for the Mc Cabe site and 45 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.


If you have any questions, please contact me at (760) 427-4685

Sincerely,

Francisco Rodriguez

Chief Operator

Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

July 8, 2022

Attention: Mrs. Fischer

Subject: June 2022 Monthly Report

On the billing cycle ending on the 23rd of June 34,243,000 gallons of water were used by our consumers, an average of 1,105,000 gallons was used per day.

On June 22, 2022, collected Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on July 6, 2022 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 59 ppb for the Mc Cabe site and 45 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

On June 28, 2022 started draining pond #2 for maintenance purposes. Once the pond sludge is dried it will be cleaned and inspected for any ruptures on the plastic liner.


If you have any questions, please contact me at (760) 427-4685

Sincerely,

Francisco Rodriguez

Chief Operator

Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

August 4, 2021

Attention: Mrs. Fischer

Subject: July 2021 Monthly Report


On the billing cycle ending on the 22nd of July 34,935,000 gallons of water were used by our consumers, an average of 1,164,000 gallons was used per day.

On July 14, 2021, collected Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on July 29, 2021 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 55 ppb for the Mc Cabe site and 42 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H  
Heber CA 92249  
Tel:(760)482-2440 • Fax (760)353-9951  
[www.heber.ca.gov](http://www.heber.ca.gov)

September 10, 2021

Attention: Mrs. Fischer

Subject: August 2021 Monthly Report


On the billing cycles ending on the 21st of August 33,417,000 gallons of water were used by our consumers, an average of 1,114,000 gallons was used per day.

On August 12, 2021, collected Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on August 19, 2021 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 56 ppb for the Mc Cabe site and 43 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H  
Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

October 12, 2021

Attention: Mrs. Fischer

Subject: September 2021 Monthly Report

On the billing cycles ending on the 21st of September 31,654,000 gallons of water were used by our consumers, an average of 1,273,000 gallons was used per day.

On September 15, 2021 collected third quarter TTHM's samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on September 27, 2021 and were below the maximum contaminant level (MCL) for the both sites. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and for the month of September of 2021 we attained a RAA of 55 ppb for the Mc Cabe Cove site and 42 ppb for the Little Field site. Heber Public Utility District is in compliance with State and Federal water regulations.


On October 1, 2021 notice an expansion joint in deteriorating conditions at the water distribution outlet. The expansion joint is used in order for the ductile iron pipes have some movement and prevents the pipes from breaking in an event of an earthquake. A new expansion joint has been ordered and will be installed as soon as it is delivered. The replacement of this expansion joint will be at night as it will require to turn off the distribution pumps and the use of a six-inch pump to keep an adequate water distribution pressure.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

Francisco Rodriguez  
Chief Operator

Heber Public Utility District



## Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

Nov 9, 2021

Attention: Mrs. Fischer

Subject: October 2021 Monthly Report

On the billing cycles ending on the 21st of October 26,699,000 gallons of water were used by our consumers, an average of 890,000 gallons was used per day.

On October 13, 2021 collected fourth quarter TTHM's samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on October 26, 2021 and were below the maximum contaminant level (MCL) for the both sites. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and for the 4th of 2021 we attained a RAA of 54 ppb for the Mc Cabe Cove site and 39 ppb for the Little Field site. Heber Public Utility District is in compliance with State and Federal water regulations.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H  
Heber CA 92249  
Tel:(760)482-2440 • Fax (760)353-9951  
[www.heber.ca.gov](http://www.heber.ca.gov)

December 9, 2021

Attention: Mrs. Fischer

Subject: November 2021 Monthly Report

On the billing cycles ending on the 21<sup>st</sup> of November 24,333,000 gallons of water were used by our consumers, an average of 785,000 gallons was used per day.


On November 17, 2021, collected the monthly Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on December 2, 2021 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 54 ppb for the McCabe site and 40 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

On November 30, 2021 Filter #1 underdrains were exposed do to backwash irregularities. Upon inspection it was observed that the underdrains were slightly cracked and that the grout material between the underdrain blocks were loose and, in some areas, broken. We have reached Westech, the manufacture of the filter and informed them of the situation. Westech will send us their recommendation of what is needed to make the appropriate repairs.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

January 7, 2022

Attention: Mrs. Fischer

Subject: December 2021 Monthly Report

On the billing cycles ending on the 21st of December 19,724,000 gallons of water were used by our consumers, an average of 657,000 gallons was used per day.

On December 22, 2021, collected the monthly Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on December 29, 2021 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 54 ppb for the McCabe site and 40 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District