



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H
Heber CA 92249
Tel: (760) 482-2440 • Fax (760) 353-9951
www.heber.ca.gov

June 4, 2025

Attention: Madeline
General Manager

Subject: May 2025 Monthly Report

On the billing cycle ending on the 21ST of May 30,161,000 gallons of water were used by our consumers, an average of 1,005,000 gallons was used per day.

On May 20, 2025, collected Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on May 27, 2025 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 62 ppb for the Mc Cabe site and 43 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

If you have any questions, please contact me at (760) 427-4685

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez", is written over a horizontal line.

Francisco Rodriguez
Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel: (760) 482-2440 • Fax (760) 353-9951

June 04, 2025

Attention: Madeline
General Manager

Subject: Water Distribution Report May 2025

A) Water breaks (0)

B) Service Leak (0)

C) Work orders (53)


DIS - DISCONNECT	7
BEES - BEES IN WATER METER	1
TEMP - TEMP SHUT OFF FOR REPAIR	1
LEAK - METER LEAK	2
ONCALL - ONCALL OPERATOR WAS CALLED	1
HYDRANT - HYDRANT LEAK	1
SWR - SEWER PLUG	1
CON - CONNECT	3
OCC - OCCUPANT CHANGE	3
MC - METER CHANGE	33

TOTAL ALL CODES	53
-----------------	----

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Water Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H

Heber, CA 92249

TEL. (760) 482-2440 • FAX (760) 353-9951

www.heber.ca.gov

June 6, 2025

Attention: Madeline Dessert
General Manager

SUBJECT: Heber W.W.T.P. Operations from April 20, 2025 through May 20, 2025

- A. Major violations: (NONE)
- B. Minor violations: (NONE)
- C. Major sewer spills: (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System: Operating fine. Self-cleaning.
- F. Vactor Truck: Vactor truck was used in May 2025, to clean sewers on West Second St, Sparrow, and Robin St. It was also used to expose a water main leak in the alley between Mallard and Pheasant Ct.
- G. TOTAL OF MILES OF SEWER LINES CLEANED OR VIDEOED: 5,100 Ft (0.96) miles.
- H. From: April 20, 2025 through May 20, 2025 Heber Wastewater Plant received and treated 13.766 MG.
- I. HPUD did not exceed the daily maximum flow (1.2 MGD) as of May 20, 2025.

Sincerely,

Matthew Hughes
Lead Operator
Heber Public Utility District

Heber Public Utility District is an equal opportunity provider and employer



HEBER PUBLIC UTILITY DISTRICT

Water & Wastewater Treatment Plants and Billing Report Billing Period : APRIL 21, 2025 thru MAY 21, 2025

	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced	10% Senior Discount
Month & Year	Gallons Produced	Gallons Invoiced	Gallons not invoiced	Water not accounted	Influent	Water	Sewer	Trash	# of Accounts receiving the discount
May-24	28,843,000	27,127,172	2,558,028	-842,200	14,607,000	\$ 142,812.36	\$ 117,203.17	\$ 57,081.99	159 Accounts
Jun-24	37,690,000	33,120,546	1,813,047	2,756,407	15,141,000	\$ 164,837.06	\$ 117,141.44	\$ 57,132.60	160 Accounts
Jul-24	39,157,000	35,420,583	2,896,894	839,523	14,417,000	\$ 167,879.73	\$ 117,572.65	\$ 59,335.38	160 Accounts
Aug-24	37,804,000	31,835,694	2,348,695	3,619,611	13,568,000	\$ 157,634.05	\$ 117,426.53	\$ 59,321.68	160 Accounts
Sep-24	36,091,000	32,568,946	2,391,872	1,130,182	14,684,000	\$ 158,946.99	\$ 117,782.09	\$ 59,327.03	166 Accounts
Oct-24	30,006,000	28,543,493	2,209,711	-747,204	17,647,000	\$ 146,026.20	\$ 117,155.53	\$ 59,391.78	166 Accounts
Nov-24	24,426,000	24,006,473	1,978,551	-1,559,024	14,475,000	\$ 137,174.61	\$ 116,866.31	\$ 59,398.74	166 Accounts
Dec-24	19,145,000	21,611,874	1,346,649	-3,813,523	13,666,000	\$ 134,472.59	\$ 116,784.19	\$ 59,569.57	166 Accounts
Jan-25	18,836,000	19,157,768	1,531,243	-1,853,011	12,692,000	\$ 132,753.07	\$ 116,527.28	\$ 59,550.93	166 Accounts
Feb-25	19,618,000	20,080,938	1,664,481	-2,127,419	13,489,000	\$ 132,926.63	\$ 116,552.04	\$ 59,527.34	166 Accounts
Mar-25	20,043,000	20,390,552	2,187,885	-2,535,437	12,360,000	\$ 130,169.73	\$ 116,705.53	\$ 59,484.98	166 Accounts
Apr-25	25,993,000	25,137,709	2,961,623	-2,106,332	13,863,000	\$ 135,876.87	\$ 116,928.52	\$ 59,542.32	167 Accounts
May-25	30,161,000	27,730,823	3,556,069	-1,125,892	13,766,000	\$ 140,716.70	\$ 117,062.63	\$ 59,627.47	170 Accounts

Totals includes billing for final accounts

To the best of my knowledge, the information is true and correct.

Liz German
Liz German
Office Senior Clerk

6/9/25
Date

**** TOTALS BY JOB CODE ****

JOB CODE	TOTAL COMPLETED	TOTAL OUTSTANDING	TOTAL NEW	TOTAL PENDING	TOTAL VOID
DIS - DISCONNECT	7	0	0	0	11
LEAK - METER LEAK	2	1	0	0	0
TEMP - TEMP SHUT OF FOR REPAI	1	0	0	0	0
CON - CONNECT	3	0	0	0	0
HYDRT - HYDRANT LEAK	1	1	0	0	0
OCC - OCCUPANT CHANGE	3	0	0	0	0
ONCAL - ONCALL OPERATOR WAS CA	1	0	0	0	0
SWR - SEWER PLUG UP	1	0	0	0	0
MC - METER CHANGE	33	0	0	0	4
BES - BES IN METER	1	0	0	0	0
WTR - SERVICE LINE LEAK	0	2	0	0	0
INFO - TEST METER	0	1	0	0	0
TOTAL ALL CODES	53	5	0	0	15