



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

www.heber.ca.gov

March 4, 2025

Attention: Madeline
General Manager

Subject: February 2024 Monthly Report

On the billing cycle ending on the 22nd of February 19,618,000 million gallons of water were used by our consumers, an average of 632,000 thousand gallons was used per day.

On February 11, 2025, collected Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on February 18, 2025 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 55 ppb for the Mc Cabe site and 42 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

If you have any questions, please contact me at (760) 427-4685

Respectfully,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez

Chief Operator

Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

www.heber.ca.gov

March 8, 2025

Attention: Madeline
General Manager

Subject: Water Distribution Report February 2025

a) Water Breaks (0)

b) Service Leak (0)

c) Work Orders (27)


DIS - DISCONNECT.....	5
CON - CONNECT.....	5
INFO - TEST METER.....	1
OCC - OCCUPANT CHANGE.....	5
LEAK - METER LEAK.....	6
WTR - SERVICE LINE LEAK.....	1
HYDRT - HYDRANT LEAK.....	0
TEMP - TEMP SHUT OFF FOR REPAIR.....	1
SWR - SEWER PLUG UP.....	2
PRSUR - TEST WATER PRESSURE.....	1

TOTAL ALL CODES..... (27)

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez
Chief Operator
Heber Public Utility District



Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H

Heber, CA 92249

TEL. (760) 482-2440 • FAX (760) 353-9951

www.heber.ca.gov

March 14, 2025

Attention: Madeline Dessert
General Manager

SUBJECT: Heber W.W.T.P. Operations from January 20, 2025 through February 20, 2025

- A. Major violations: (NONE)
- B. Minor violations: (1) Effluent Bacti-Sample above requirement. (Permit Limit is <400 MPN; Result 920MPN)
- C. Major sewer spills: (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System: Operating fine. Self-cleaning.
- F. Vactor Truck: Vactor truck was used on February 2025, clean clarifiers and UV channel at wastewater plant.
- G. TOTAL OF MILES OF SEWER LINES CLEANED OR VIDEOED: 0 miles.
- H. From: January 20, 2025 through February 20, 2025 Heber Wastewater Plant received and treated 13.489 MG.
- I. HPUD did not exceed the daily maximum flow (1.2 MGD) as of January 20, 2025.
- J. Two electric drive motors were removed, rebuilt and reinstalled at wastewater aeration basin.

Sincerely,

Francisco Rodriguez
Chief Operator
Heber Public Utility District



HEBER PUBLIC UTILITY DISTRICT

Water & Wastewater Treatment Plants and Billing Report Billing Period : JANUARY 20, 2025 thru FEBRUARY 20, 2025

	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced	10% Senior Discount
Month & Year	Gallons Produced	Gallons Invoiced	Gallons not invoiced	Water not accounted	Influent	Water	Sewer	Trash	# of Accounts receiving the discount
Feb-24	15,667,000	16,178,248	2,054,462	-2,565,710	17,779,000	\$ 124,392.83	\$ 116,000.69	\$ 55,382.61	160 Accounts
Mar-24	20,322,000	21,108,650	1,837,250	-2,623,900	16,197,000	\$ 129,995.46	\$ 116,490.45	\$ 56,706.82	160 Accounts
Apr-24	25,549,000	24,474,159	2,026,456	-951,615	16,037,000	\$ 137,142.31	\$ 116,538.21	\$ 57,140.44	159 Accounts
May-24	28,843,000	27,127,172	2,558,028	-842,200	14,607,000	\$ 142,812.36	\$ 117,203.17	\$ 57,081.99	159 Accounts
Jun-24	37,690,000	33,120,546	1,813,047	2,756,407	15,141,000	\$ 164,837.06	\$ 117,141.44	\$ 57,132.60	160 Accounts
Jul-24	39,157,000	35,420,583	2,896,894	839,523	14,417,000	\$ 167,879.73	\$ 117,572.65	\$ 59,335.38	160 Accounts
Aug-24	37,804,000	31,835,694	2,348,695	3,619,611	13,568,000	\$ 157,634.05	\$ 117,426.53	\$ 59,321.68	160 Accounts
Sep-24	36,091,000	32,568,946	2,391,872	1,130,182	14,684,000	\$ 158,946.99	\$ 117,782.09	\$ 59,327.03	166 Accounts
Oct-24	30,006,000	28,543,493	2,209,711	-747,204	17,647,000	\$ 146,026.20	\$ 117,155.53	\$ 59,391.78	166 Accounts
Nov-24	24,426,000	24,006,473	1,978,551	-1,559,024	14,475,000	\$ 137,174.61	\$ 116,866.31	\$ 59,398.74	166 Accounts
Dec-24	19,145,000	21,611,874	1,346,649	-3,813,523	13,666,000	\$ 134,472.59	\$ 116,784.19	\$ 59,569.57	166 Accounts
Jan-25	18,836,000	19,157,768	1,531,243	-1,853,011	12,692,000	\$ 132,753.07	\$ 116,527.28	\$ 59,550.93	166 Accounts
Feb-25	19,618,000	20,080,938	1,664,481	-2,127,419	13,489,000	\$ 132,926.63	\$ 116,552.04	\$ 59,527.34	166 Accounts

Totals includes billing for final accounts

To the best of my knowledge, the information is true and correct.

Liz German
Liz German
Office Senior Clerk

3/13/25
Date

**** TOTALS BY JOB CODE ****

JOB CODE	TOTAL COMPLETED	TOTAL OUTSTANDING	TOTAL NEW	TOTAL PENDING	TOTAL VOID
DIS - DISCONNECT	5	0	0	0	32
LEAK - METER LEAK	6	2	0	0	0
OCC - OCCUPANT CHANGE	5	0	0	0	0
CON - CONNECT	5	0	0	0	0
SWR - SEWER PLUG UP	2	0	0	0	0
INFO - TEST METER	1	2	0	0	0
PRSUR - TEST WATER PRESSURE	1	0	0	0	0
WTR - SERVICE LINE LEAK	1	0	0	0	0
MISC - MISC REPORT	0	1	0	0	0
TEMP - TEMP SHUT OF FOR REPAI	1	1	0	0	0
HYDRT - HYDRANT LEAK	0	1	0	0	0
TOTAL ALL CODES	27	7	0	0	32