



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H  
Heber CA 92249  
Tel:(760)482-2440 • Fax (760)353-9951  
[www.heber.ca.gov](http://www.heber.ca.gov)

March 8, 2024

Attention: Madeline  
General Manager

Subject: February 2024 Monthly Report

On the billing cycle ending on the 22nd of February 16,418,000 million gallons of water were used by our consumers, an average of 505,000 thousand gallons was used per day.

On February 22, 2024, collected Trihalomethanes (TTHM's) samples and were sent to Clinical Lab of San Bernardino for analysis. The results came in on March 27, 2024 and were below the maximum contaminant levels (MCL) for TTHM's. The running annual average (RAA) MCL for TTHM's is 80 parts per billion (ppb) and we attained 57 ppb for the Mc Cabe site and 44 ppb for the Little Field site. Heber Public Utility District continues to be in compliance with the State and Federal Water Regulations.

If you have any questions, please contact me at (760) 427-4685

Respectfully,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District



# Heber Public Utility District

1078 Dogwood Rd. Suite 103 • PO Box H

Heber CA 92249

Tel:(760)482-2440 • Fax (760)353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

March 8, 2024

Attention: Madeline  
General Manager

Subject: Water Distribution Report February 2024

- a) Water Breaks ( 0 )
- b) Service Leak ( 1 )
  - 1. 25 Mustang Road
- c) Work Orders ( 54 )


FIREF - ENCODER/FIREFLY.....	7
MC - METER CHANGE.....	18
ODOR - (BAD TASTE/SMELL.....	1
DIS - DISCONNECT.....	2
CON - CONNECT.....	1
INFO - TEST METER.....	9
OCC - OCCUPANT CHANGE.....	2
LEAK - METER LEAK.....	7
WTR - SERVICE LINE LEAK.....	2
HYDRT - HYDRANT LEAK.....	2
TEMP - TEMP SHUT OFF FOR REPAIR.....	1
SWR - SEWER PLUG UP.....	1
PRSUR - TEST WATER PRESSURE.....	1

TOTAL ALL CODES..... (54)

Sincerely,

A handwritten signature in blue ink, appearing to read "Francisco Rodriguez".

Francisco Rodriguez  
Chief Operator  
Heber Public Utility District



## Heber Public Utility District

1078 Dogwood Rd., Suite 103 • P. O. Box H

Heber, CA 92249

TEL. (760) 482-2440 • FAX (760) 353-9951

[www.heber.ca.gov](http://www.heber.ca.gov)

March 11, 2024

Attention: Madeline Dessert  
General Manager

SUBJECT: Heber W.W.T.P. Operations from January 20, 2024 through February 20, 2024.

- A. Major violations: (NONE)
- B. Minor violations: (NONE)
- C. Major sewer spills: (NONE)
- D. Main sewer Plugs: (NONE)
- E. UV System: Operating fine. Self-cleaning.
- F. Vactor Truck: No use of the vactor truck this monthly cycle. Vactor truck was under repair.
- G. TOTAL OF MILES OF SEWER LINES CLEANED OR VIDEOED: 0.
- H. From January 20, 2024 through February 20, 2024: Heber Wastewater Plant received and treated 17.779 MG.
- I. HPUD did not exceed the daily maximum flow (1.2 MGD) as of February 20, 2024.

Sincerely,

A handwritten signature in blue ink, appearing to be "E. Gonzalez".

Edoardo S. Gonzalez  
Wastewater Plant Lead Operator



HEBER PUBLIC UTILITY DISTRICT

Water & Wastewater Treatment Plants and Billing Report  
 Billing Period : January 20, 2024 THRU February 20, 2024

Month & Year	Water		HPUD Offices/Parks	Difference Water	Sewer	Invoiced	Invoiced	Invoiced	10% Senior Discount
	Gallons Produced	Gallons Invoiced	Gallons not invoiced	Water not accounted	Influent	Water	Sewer	Trash	# of Accounts receiving the discount
Feb-23	14,866,000	17,436,262	1,819,310	-4,389,572	15,419,000	\$ 125,185.58	\$ 115,755.26	\$ 48,228.82	160 Accounts
Mar-23	14,912,000	18,525,257	1,956,134	-5,569,391	16,565,000	\$ 126,234.37	\$ 116,209.30	\$ 48,749.15	160 Accounts
Apr-23	19,578,000	23,851,240	2,467,680	-6,740,920	13,959,000	\$ 137,270.06	\$ 116,752.65	\$ 54,129.28	160 Accounts
May-23	24,937,000	27,283,599	2,091,376	-4,437,975	13,429,000	\$ 145,124.77	\$ 116,710.16	\$ 54,054.90	160 Accounts
Jun-23	28,781,000	29,925,186	2,454,108	-3,598,294	14,212,000	\$ 149,604.48	\$ 117,451.77	\$ 54,154.44	160 Accounts
Jul-23	30,540,000	33,019,108	2,481,826	-4,960,934	12,877,000	\$ 158,940.92	\$ 117,756.38	\$ 55,755.67	160 Accounts
Aug-23	31,134,000	29,923,590	2,513,664	-1,303,254	13,991,000	\$ 150,960.04	\$ 117,671.85	\$ 55,810.93	160 Accounts
Sep-23	34,405,000	27,531,530	2,616,579	4,256,891	13,723,000	\$ 143,774.19	\$ 117,357.33	\$ 55,767.32	160 Accounts
Oct-23	30,110,000	27,412,985	2,231,252	465,763	14,544,000	\$ 144,521.19	\$ 117,579.77	\$ 55,759.60	160 Accounts
Nov-23	24,697,000	23,117,991	1,764,615	-185,606	15,743,000	\$ 137,195.23	\$ 117,267.22	\$ 55,685.68	160 Accounts
Dec-23	20,976,000	21,708,288	2,543,739	-3,276,027	14,691,000	\$ 135,839.85	\$ 116,781.70	\$ 55,576.30	160 Accounts
Jan-24	20,638,366	18,135,000	1,825,771	677,595	15,560,000	\$ 134,297.40	\$ 117,302.21	\$ 55,426.19	160 Accounts
<b>Feb-24</b>	<b>15,667,000</b>	<b>16,178,248</b>	<b>2,054,462</b>	<b>-2,565,710</b>	<b>17,779,000</b>	<b>\$ 124,392.83</b>	<b>\$ 1,160,006.86</b>	<b>\$ 55,382.61</b>	<b>160 Accounts</b>

Totals includes billing for final accounts

To the best of my knowledge, the information is true and correct.

*Liz German*  
 Liz German  
 Office Senior Clerk

3/11/24  
 Date

## \*\*\*\* TOTALS BY JOB CODE \*\*\*\*

<u>JOB CODE</u>	<u>TOTAL COMPLETED</u>	<u>TOTAL OUTSTANDING</u>	<u>TOTAL NEW</u>	<u>TOTAL PENDING</u>	<u>TOTAL VOID</u>
SWR - SEWER PLUG UP	1	0	0	0	0
INFO - TEST METER	9	0	0	0	0
TEMP - TEMP SHUT OF FOR REPAI	1	0	0	0	0
OCC - OCCUPANT CHANGE	2	0	0	0	0
MC - METER CHANGE	18	0	0	0	0
WTR - SERVICE LINE LEAK	2	0	0	0	0
FIRRF - ENCODER/FIRELY	7	0	0	0	0
LEAK - METER LEAK	7	0	0	0	0
PRSUR - TEST WATER PRESSURE	1	0	0	0	0
DIS - DISCONNECT	2	0	0	0	11
CON - CONNECT	1	0	0	0	0
ODOR - ODOR (BAD TASTE/SMELL)	1	0	0	0	0
HYDRT - HYDRANT LEAK	2	0	0	0	0
<u>TOTAL ALL CODES</u>	<u>54</u>	<u>0</u>	<u>0</u>	<u>0</u>	<u>11</u>